

**CERTIFICATE
EU-TYPE EXAMINATION
Module: B**

No. 181299355

issued in accordance with Annex No. III, Part 1, to Regulation (EU) 2016/426 of the European Parliament and of the Council

Manufacturer: **G20 ENGINEERING S.R.L, CARPANETO PIACENTINO (PC)
LOCALITA CAMPOGRANDE No.13, ZIP CODE: 29013, Italy**

Product: **Wall Hung condensing gas boilers burning gaseous fuels,
type „C₁₃“, „C₃₃“, „C₄₃“, „C₅₃“, category II_{2H3P}
GRUPPO IMAR
SUIT MR24 KONDENS – SUIT MN24 KONDENS – SUIT MR28 KONDENS –
SUIT MN28 KONDENS - SUIT CR24 IN-OUT KONDENS – SUIT CR28 IN-
OUT KONDENS**

Models: **SUIT MR24: 24kW CONDENSING GAS BOILERS FOR CH AND DHW
SUIT MN24: 24kW CONDENSING GAS BOILERS FOR CH ONLY
SUIT MR28: 28kW CONDENSING GAS BOILERS FOR CH AND DHW
SUIT MN28: 28kW CONDENSING GAS BOILERS FOR CH ONLY
SUIT CR24: 24kW CONDENSING GAS BOILERS FOR CH AND DHW
FOR INDOOR-OUTDOOR
SUIT CR28: 28 kW CONDENSING GAS BOILERS
FOR CH AND DHW FOR INDOOR-OUTDOOR**

Product ID Number: **CE-1299CT0355**

This certificate TSÚ Piešťany, š.p. as Notified Body confirms the conformity the tested sample with the essential safety requirements of the following European Legislation:

**REGULATION (EU) 2016/426 OF THE EUROPEAN PARLIAMENT AND OF THE COUNCIL
on appliances burning gaseous fuels**

Certificate has been issued on the basis of this document: Conformity assessment report
No. 180500295/1 dated on 11th of December 2018

Issue date: 12th of December 2018

Expiry date: (following procedure according to Module C2)

Issue: 1



Ing. Dušan Hanko
on behalf of TSU Piešťany, š.p., NB 1299

Specification

Countries of destination		Supply pressures	Appliances categories
AT	Austria	20 mbar	I _{2H}
BE	Belgium	37 mbar	I _{3P}
BG	Bulgaria	20 mbar, 37 mbar	II _{2H3P}
CH	Switzerland	20 mbar, 37 mbar	II _{2H3P}
CZ	Czech Republic	20 mbar, 37 mbar	II _{2H3P}
DK	Denmark	20 mbar	I _{2H}
EE	Estonia	20 mbar, 37 mbar	II _{2H3P}
ES	Spain	20 mbar, 37 mbar	II _{2H3P}
FI	Finland	20 mbar	I _{2H}
GB	Great Britain	20 mbar, 37 mbar	II _{2H3P}
GR	Greece	20 mbar, 37 mbar	II _{2H3P}
HU	Hungary	25 mbar, 37 mbar	II _{2H3P}
IE	Ireland	20 mbar, 37 mbar	II _{2H3P}
IT	Italy	20 mbar	I _{2H}
LT	Lithuania	20 mbar	I _{2H}
LV	Latvia	20 mbar, 37 mbar	II _{2H3P}
PL	Poland	37 mbar	I _{3P}
PT	Portugal	20 mbar, 37 mbar	II _{2H3P}
RO	Romania	20 mbar, 37 mbar	II _{2H3P}
SK	Slovakia	20 mbar, 37 mbar	II _{2H3P}
SI	Slovenia	20 mbar, 37 mbar	II _{2H3P}
SE	Sweden	20 mbar	I _{2H}
TR	Turkey	20 mbar, 37 mbar	II _{2H3P}

European harmonized standards used for the conformity assessment:

EN 15502-1: 2012; A1: 2015

EN 15502-2-1: 2012; A1: 2016

EN 15502-2-2: 2014

The rules for use of this certificate.

It is forbidden to modify, amend or rewrite the data in the certificate.

This certificate cannot be used as a certificate for product, where a change influencing conformity with the applied normative documents and regulations was done without approval of the TSÚ Piešťany, š.p..

Manufacturer have to choose together with the module B either module C2 or module D. In the separate module B is impossible to affix the CE marking with Notified Body Number for the product /s.

